

CONTRACTOR TO VERIFY ALL
DIMENSIONS IN FIELD



- * 8' minimum length for sheathing on one side.
4' minimum length for sheathing on both sides.
- * Meet code for size and spacing of studs and plates.
- * Sill plate anchorage as follows: Pressure treated 2X with 1/2" Dia x 10" AB within 6" each end and on 6'-0" centers if over stemwall.
- * Sole plate anchorage as follows: 2X plate fastened with 3-16d box nails at 16" centers max.
- * Sheathing as follows: 1/2" Gypsum with 2X normal blocking at all joints. Use 1 1/4" drywall nails or screws. Place fasteners at 4" centers on edges and 8" centers in field.

- * 4' minimum length
- * Meet code for size and spacing of studs and plates.
- * Sill plate anchorage as follows: Pressure treated 2X with 1/2" Dia x 10" AB within 6" each end and on 6'-0" centers if over stem wall.
- * Sole plate anchorage as follows: 2X plate fastened with 3-16d box nails at 16" centers max.
- * Sheathing as follows: 7/16" OSB APA rated sheathing with 2X normal blocking at all joints. Use 8d common nails or 8d galvanized box nails. Place fasteners at 3" centers on edges and 6" centers in field.

FOUNDATION PLAN SCALE: 1/4" = 1'-0"

4 SHEETS